



Drinking-Water System Number:	220008284
Drinking-Water System Name:	SAM Well Supply
Drinking-Water System Owner:	Municipality of Central Huron
Drinking-Water System Category:	Small Municipal Residential
Period being reported:	January 1 to December 31 2009

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [] No [X]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <table border="1" style="width: 100%;"> <tr> <td>Municipal Office 23 Albert St. Clinton Ontario</td> </tr> <tr> <td>Utilities Work Centre 17 Park Lane Clinton Ontario</td> </tr> </table>	Municipal Office 23 Albert St. Clinton Ontario	Utilities Work Centre 17 Park Lane Clinton Ontario	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
Municipal Office 23 Albert St. Clinton Ontario			
Utilities Work Centre 17 Park Lane Clinton Ontario			

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No []



**Ontario Drinking-Water Systems Regulation O. Reg. 170/03
SAM Well Supply Annual Report 2009**

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The SAM Well Supply is located at 77301 Forest Ridge Road. There is a single drilled groundwater well, approximately 159mm diameter by 59.44m deep, with a submersible well pump.
Treatment consists of sodium hypochlorite disinfection in a 33m of 300 mm contact water main. Sodium silicate is added for iron sequestering.
Storage is provided by 3 hydropneumatic pressure tanks. Standby power is provided by a natural gas powered generator with automatic power transfer.
The distribution approximately 14 year around residential connections.

List all water treatment chemicals used over this reporting period

sodium hypochlorite
sodium silicate

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Feb 9, 2009	Sodium	22	mg/L	Notify & resample	Feb 19, 2009



**Ontario Drinking-Water Systems Regulation O. Reg. 170/03
SAM Well Supply Annual Report 2009**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 - 0	0 - 0	0	
Treated	52	0 - 0	0 - 0	52	0 - 46
Distribution	52	0 - 0	0 - 0	52	0 - 160

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	12	0.10 – 0.59 NTU
Chlorine	8760	0.3 – 1.8 mg/L
Fluoride (If the DWS provides fluoridation)	na	

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Feb 9, 2009	ND	µg/L	No
Arsenic	Feb 9, 2009	8	µg/L	No
Barium	Feb 9, 2009	49	µg/L	No
Boron	Feb 9, 2009	120	µg/L	No
Cadmium	Feb 9, 2009	ND	µg/L	No
Chromium	Feb 9, 2009	ND	µg/L	No
*Lead	See table below			
Mercury	Feb 9, 2009	ND	mg/L	No
Selenium	Feb 9, 2009	ND	µg/L	No
Sodium	Feb 9, 2009	22	mg/L	Yes
Uranium	Feb 9, 2009	0.7	µg/L	No



Ontario Drinking-Water Systems Regulation O. Reg. 170/03 SAM Well Supply Annual Report 2009

Fluoride	Feb 9, 2009	1.5	mg/L	No
Nitrite	Nov 23, 2009	ND	mg/L	No
Nitrate	Nov 23, 2009	ND	mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	0		
Distribution	0		

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Feb 9, 2009	ND	µg/L	No
Aldicarb	Feb 9, 2009	ND	µg/L	No
Aldrin + Dieldrin	Feb 9, 2009	ND	µg/L	No
Atrazine + N-dealkylated metabolites	Feb 9, 2009	ND	µg/L	No
Azinphos-methyl	Feb 9, 2009	ND	µg/L	No
Bendiocarb	Feb 9, 2009	ND	µg/L	No
Benzene	Feb 9, 2009	ND	µg/L	No
Benzo(a)pyrene	Feb 9, 2009	ND	µg/L	No
Bromoxynil	Feb 9, 2009	ND	µg/L	No
Carbaryl	Feb 9, 2009	ND	µg/L	No
Carbofuran	Feb 9, 2009	ND	µg/L	No
Carbon Tetrachloride	Feb 9, 2009	ND	µg/L	No
Chlordane (Total)	Feb 9, 2009	ND	µg/L	No
Chlorpyrifos	Feb 9, 2009	ND	µg/L	No
Cyanazine	Feb 9, 2009	ND	µg/L	No
Diazinon	Feb 9, 2009	ND	µg/L	No
Dicamba	Feb 9, 2009	ND	µg/L	No
1,2-Dichlorobenzene	Feb 9, 2009	ND	µg/L	No
1,4-Dichlorobenzene	Feb 9, 2009	ND	µg/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Feb 9, 2009	ND	µg/L	No
1,2-Dichloroethane	Feb 9, 2009	ND	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	Feb 9, 2009	ND	µg/L	No



**Ontario Drinking-Water Systems Regulation O. Reg. 170/03
SAM Well Supply Annual Report 2009**

Dichloromethane	Feb 9, 2009	ND	µg/L	No
2-4 Dichlorophenol	Feb 9, 2009	ND	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Feb 9, 2009	ND	µg/L	No
Diclofop-methyl	Feb 9, 2009	ND	µg/L	No
Dimethoate	Feb 9, 2009	ND	µg/L	No
Dinoseb	Feb 9, 2009	ND	µg/L	No
Diquat	Feb 9, 2009	ND	µg/L	No
Diuron	Feb 9, 2009	ND	µg/L	No
Glyphosate	Feb 9, 2009	ND	µg/L	No
Heptachlor + Heptachlor Epoxide	Feb 9, 2009	ND	µg/L	No
Lindane (Total)	Feb 9, 2009	ND	µg/L	No
Malathion	Feb 9, 2009	ND	µg/L	No
Methoxychlor	Feb 9, 2009	ND	µg/L	No
Metolachlor	Feb 9, 2009	ND	µg/L	No
Metribuzin	Feb 9, 2009	ND	µg/L	No
Monochlorobenzene	Feb 9, 2009	ND	µg/L	No
Paraquat	Feb 9, 2009	ND	µg/L	No
Parathion	Feb 9, 2009	ND	µg/L	No
Pentachlorophenol	Feb 9, 2009	ND	µg/L	No
Phorate	Feb 9, 2009	ND	µg/L	No
Picloram	Feb 9, 2009	ND	µg/L	No
Polychlorinated Biphenyls(PCB)	Feb 9, 2009	ND	µg/L	No
Prometryne	Feb 9, 2009	ND	µg/L	No
Simazine	Feb 9, 2009	ND	µg/L	No
THM (NOTE: show latest annual average)	2009	0.0056	mg/L	No
Temephos	Feb 9, 2009	ND	µg/L	No
Terbufos	Feb 9, 2009	ND	µg/L	No
Tetrachloroethylene	Feb 9, 2009	ND	µg/L	No
2,3,4,6-Tetrachlorophenol	Feb 9, 2009	ND	µg/L	No
Triallate	Feb 9, 2009	ND	µg/L	No
Trichloroethylene	Feb 9, 2009	ND	µg/L	No
2,4,6-Trichlorophenol	Feb 9, 2009	ND	µg/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Feb 9, 2009	ND	µg/L	No
Trifluralin	Feb 9, 2009	ND	µg/L	No
Vinyl Chloride	Feb 9, 2009	ND	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
fluoride	1.5	mg/L	Feb 9, 2009